

SECTION 1107.14 FIRE PITS.

SUBD. 1. FIRE PITS.

Free-standing or in-ground fire pits shall comply with the following:

- A. Shall not exceed a diameter of three (3) feet.
- B. Materials burned shall consist of wood, coal, charcoal or brush only.
- C. Shall not be located within twenty-five (25) feet of combustible walls, roofs, or other combustible material; building openings; or property lines, and shall be in accordance with the Minnesota State Uniform Fire Code, as amended.

(Ord. 15-03, Section 1107.14, Adopted June 15, 2015.)